

HALOACETIC ACIDS: LRAA MCL = 60 PPB

MILFORD WATER COMPANY

				DBP01	DBP02	DBP03	DBP04	DBP06
Location:	QA	RAA	266 Purchase St.	230 Main St.	1 Countryside Dr.	22 Beaver St.	159 South Main St.	
Q2-2010 (06/09/10):	23.04	19	4.3	41.0	54.0	14.0	1.9	
Q3-2010 (09/29/10):	6.06	15	2.3	6.7	8.5	11.0	1.8	
Q4-2010 (12/21/10):	38.97	21	0.7	80.0	61.0	46.0	7.2	
Q1-2011 (03/08/11):	22.30	23	5.0	57.0	8.5	30.0	11.0	
Q2-2011 (06/28/11):	24.92	23	8.1	64.0	13.0	31.0	8.5	
Q3-2011 (08/04/11):	29.04	29						
Q3-2011 (08/25/11):								
Q3-2011 (09/22/11):			6.7	72.2	24.0	38.3	4.0	
Q4-2011 (12/23/11):	20.34	24	10.4	31.1	20.8	37.2	2.2	
Q1-2012 (02/23/12):	23.96	25	15.7	29.2	32.6	35.2	7.1	
Q1-2012 (03/09/12):								
Q2-2012 (06/06/12):	19.64	23	9.8	30.9	16.4	34.9	6.2	
Q3-2012 (08/27/12):	13.32	19	3.6	22.2	8.4	23.8	8.6	
Q4-2012 (11/26/12):	12.62	17	14.2	13.2	15.0	17.6	3.1	
Q1-2013 (03/08/13):	38.12	21	58.9	31.1	45.9	42.7	12.0	
Q2-2013 (06/26/13):	2.24	17	3.0	1.9	3.6	1.9	0.8	
Q3-2013 (09/04/13):	4.60	14	3.5	6.2	5.7	6.1	1.5	
Location:	QA		105 Highland St.	68 Dilla St.	141 West St.	22 Beaver St.		
Q4-2013 (11/04/13):	6.33		8.4	5.3	5.7	5.9		
Q1-2014 (02/06/14):	5.70		6.7	3.2	7.1	5.8		
Q2-2014 (05/07/14):	12.30		13.5	7.9	15.5	12.3		
		LRAA	9.5	5.5	9.4	8.0		