

**Important Information about Your Drinking Water**  
**(Informações importantes sobre sua água potável)**  
**(Información importante sobre su agua potable)**

**Availability of Monitoring Data for Unregulated Contaminants for  
Milford Water Company**

As required by US Environmental Protection Agency (EPA), our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by EPA. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a public health protection standard.

2015 Unregulated Contaminant Test Results:

Unregulated Contaminant	Date Collected	Result or Range of Detected	Average Detected
Chlorate (ppb)	7/31/2015	93.2 – 421.6	183.5
Chromium (ppb)	10/26/2015	ND – 0.24	0.024
Chromium-6 (ppb)	10/26/2015	ND – 0.096	0.035
Strontium (ppb)	7/31/2015	55.16 – 115.1	79
Cobalt (ppb)	7/31/2015	ND – 2.43	0.24

**What should I do?**

You do not have to do anything but as our customers you have a right to know that these data are available.

You may share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, food establishments, medical facilities and businesses).

**For more information**

For additional information on your water see Milford Water Company's Consumer Confidence Report (CCR), which was delivered to you in May of this year. A copy of the CCR is also located on our web site; [www.milfordwater.com](http://www.milfordwater.com) If you have any questions about your CCR, see the contact information below.

For information on the Unregulated Contaminant Monitoring Program, visit the Milford Water Company's website [www.milfordwater.com](http://www.milfordwater.com) or the MassDEP website (<http://www.mass.gov/eea/agencies/massdep/water/drinking/water-systems-ops.html>) and navigate to Unregulated Contaminant Monitoring Program.

If you want to speak with someone at the water company about the results, please contact David Condrey, Manager at 508-473-5110 or [dcondrey@milfordwater.com](mailto:dcondrey@milfordwater.com).