

**TOTAL TRIHALOMETHANES: RAA MCL = 80 PPB**

**MILFORD WATER COMPANY**

<b>Location:</b>	<b>QA</b>	<b>RAA</b>	<b>DBP01 266 Purchase St.</b>	<b>DBP02 230 Main St.</b>	<b>DBP03 1 Countryside Dr.</b>	<b>DBP04 22 Beaver St.</b>	<b>DBP06 159 South Main St.</b>
Q2-2010 (06/09/10):	86.80	75	92.0	79.0	96.0	87.0	80.0
Q3-2010 (09/29/10):	70.80	69	69.0	77.0	80.0	77.0	51.0
Q4-2010 (12/21/10):	106.60	81	96.0	110.0	97.0	130.0	100.0
Q1-2011 (03/08/11):	67.60	83	99.0	58.0	55.0	73.0	53.0
Q2-2011 (06/28/11):	83.80	82	90.0	61.0	100.0	92.0	76.0
Q3-2011 (08/04/11):	105.65	91	125.1	76.5	122.5	112.0	127.0
Q3-2011 (08/25/11):			121.4	87.2	122.5	110.0	114.1
Q3-2011 (09/22/11):			98.8	89.4	105.6	94.2	78.5
Q4-2011 (12/23/11):	61.68	80	68.2	53.4	72.5	59.1	55.2
Q1-2012 (02/23/12):	60.42	78	90.0	56.7	87.5	46.9	73.9
Q1-2012 (03/09/12):			64.3	43.2	61.9	36.4	43.4
Q2-2012 (06/06/12):	75.89	76	91.8	60.3	88.4	64.8	80.7
Q3-2012 (08/27/12):	74.58	68	70.2	74.3	77.8	73.3	77.3
Q4-2012 (11/26/12):	64.28	69	81.6	45.3	79.5	54.0	61.0
Q1-2013 (xx/xx/13):	#DIV/0!	#DIV/0!					
Q2-2013 (xx/xx/13):	#DIV/0!	#DIV/0!					
Q3-2013 (xx/xx/13):	#DIV/0!	#DIV/0!					